

**Regulatory Compliance  
245 Albany Avenue  
Thornwood, New York 10594  
(914) 439-6513**

**Lead Concentration  
In Drinking Water**


**At**

**Hawthorne Cedar Knolls UFSD  
226 Linda Avenue  
Hawthorne, NY 10594**

**Regulatory Compliance Project Number  
HCK.1090.18.IH**

Date of Survey:  
October 10, 1018

Report Written by:  
Ernest Coon, MS, RPIH, HEM



**ABSTRACT**

The Hawthorne Cedar Knolls UFSD provided Regulatory Compliance with six (6) water samples and requested that they be tested for lead content.

The water fountains /sinks that were tested are in compliance with the NYS *Lead testing in School Drinking Water – 10 NYCRR Subpart 67-4*.

NYS *Lead Testing in School Drinking Water – 10 NYCRR Subpart 67-4*, requires a Public Notification to School Community. The results of all lead testing performed must be reported no more than 6 weeks after the school received the laboratory reports. In addition, as soon as practicable, but no more than 10 business days after the school received the laboratory reports, the school shall report data relating to test results to the Department, local health department, and State Education Department, through the Department's designated statewide electronic reporting system.

**TABLE OF CONTENTS**

<b>ABSTRACT</b>	<b>2</b>
<b>TABLE OF CONTENTS</b>	<b>3</b>
<b>1.0 INTRODUCTION</b>	<b>4</b>
<b>2.0 SAMPLING METHODOLOGY</b>	<b>4</b>
<b>3.0 RESULTS</b>	<b>4</b>
<b>4.0 10 NYCRR Subpart 67-4 REQUIREMENTS &amp; REMINDERS</b>	<b>5</b>

**Appendix**

**Appendix A**  
**Appendix B**

**Laboratory Results**  
**Implementation Guidance for Subpart 67-4 Lead Testing in**  
**School Drinking Water (FAQs)**

## 1.0 INTRODUCTION

The Hawthorne Cedar Knolls UFSD provided Regulatory Compliance with six (6) water samples and requested that they be tested for lead content.

Lead is a toxic metal that can be harmful when ingested (or inhaled), and young children are particularly sensitive to the effects of lead. Lead can get into drinking water by being present in the source water, or by interaction of the water with plumbing materials containing lead (through corrosion). Common sources of lead in drinking water include: solder, fluxes, pipes and pipefittings, fixtures, and sediments. Thus, it is possible that different water outlets in a given building could have dissimilar concentrations of lead. Lead in drinking water is regulated under the Safe Drinking Water Act (1974) as amended. The Lead Contamination Control Act (LCCA) amended the Safe Drinking Water Act and is aimed at identifying and reducing lead in drinking water in schools (and day care facilities). In April 1994, EPA prepared two guidance documents to assist municipalities in meeting the requirements of the LCCA. On September 6, 2016 the Department of Health DOH issued emergency regulations for the implementation of the new law, *Lead Testing in School Drinking Water*; the regulations became Subpart 67-4 of Title 10 (Health) of the Official Compilation of Codes, Rule and Regulations of the State of New York.

## 2.0 SAMPLING METHODOLOGY

Samples were collected in accordance with the *Lead Testing in School Drinking Water* – 10 NYCRR Subpart 67-4.3. A first-draw sample was collected in a wide mouth 250 mL bottle and collected from a cold-water outlet before the water is used. The water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours prior to collection.

## 3.0 RESULTS

The water fountains /sinks that were tested are in compliance with the NYS *Lead Testing in School Drinking Water* – 10 NYCRR Subpart 67-4.

**Table 1.0 Water Fixtures Tested**

Sample ID #	Location	Lead Conc. (mg/L)	Action Level (mg/L)	Compliant
1	Cedar Knolls Academy – Outside 108/Water Fountain	BDL	0.015	Yes
2	Cedar Knolls Academy – 202/Lab Faucet	BDL	0.015	Yes
3	Cedar Knolls Academy - 108B/Custodial Sink	BDL	0.015	Yes
4	Cedar Knolls Academy - 209F/Custodial Sink	0.012	0.015	Yes
5	Linden Hill High School – Room 109/Custodial Sink	BDL	0.015	Yes

Sample ID #	Location	Lead Conc. (mg/L)	Action Level (mg/L)	Compliant
6	Linden Hill High School – Room 208A/Custodial Sink	BDL	0.015	Yes
7	Blank	BDL	0.015	Yes

Note: BDL = Below Detectable Limit; mg/L = milligrams per liter

#### 4.0 10 NYCRR Subpart 67-4 REQUIREMENTS and REMINDERS

NYS *Lead Testing in School Drinking Water – 10 NYCRR Subpart 67-4*, requires a Public Notification to School Community. The results of all lead testing performed must be reported no more than 6 weeks after the school received the laboratory reports. In addition, as soon as practicable, but no more than 10 business days after the school received the laboratory reports, the school shall report data relating to test results to the Department, local health department, and State Education Department, through the Department's designated statewide electronic reporting system.

**Laboratory Results**



## Water Sample Report

RE: CPN HCK-10XX.18-IH - Hawthorne Cedar Knolls UFSD - Cedar Knolls Academy and  
Linden Hill High School

Date Collected: 10/10/2018

Collected By: Lou Petty

Date Received: 10/11/2018

Date Analyzed: 10/15/2018

Analyzed By: Ernest Sanchez

Signature: 

Analyte: Pb Water


Analytical Method: EPA 200.9

NYS Lab Number: 10851

Client: RegCom

245 Albany Avenue

Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
1 2584085	Cedar Knolls Academy - Outside 108	Water Fountain	BDL < 0.002 mg/L
2 2584086	Cedar Knolls Academy - Room 202	Lab Faucet	BDL < 0.002 mg/L
 2584087	Cedar Knolls Academy - Room 108B	Custodial Sink Faucet	BDL < 0.002 mg/L
4 2584088	Cedar Knolls Academy - Room 209F	Custodial Sink Faucet	0.012 mg/L
5 2584089	Linden Hill High School - Room 109	Custodial Sink Faucet	BDL < 0.002 mg/L
6 2584090	Linden Hill High School - Room 208A	Custodial Sink Faucet	BDL < 0.002 mg/L
7 2584091	Not Applicable	Blank	BDL < 0.002 mg/L



BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

Rhode Island DOH No. LA000107 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AL-709936



# RegCom

## Regulatory Compliance

---

Louis Petty  
Hawthorne Cedar Knolls UFSD  
226 Linda Avenue  
Hawthorne, NY 10594

February 27, 2017

Dear Mr. Petty,

Please find enclosed the follow-up water testing report for the 02/07/17 survey. Below is a list of the 4 sample locations that district collected on 02/07/17. Please note the non-complaint fixture, action is required.

Sample ID#/ Lab ID #	Sample Location	Medium	Concentration (mg/L)	Compliant (0.015 mg/L)
1 2476120	SR/Jr High School, Room 209A-Staff BR (Sink Faucet)	Water	0.001	YES
2 2476121	Administration, Building Basement Staff BR #2 (Sink Faucet) (counting from left to right)	Water	0.060	NO
3 2476122	Little School Room, 121/Staff Lounge (Sink Faucet)	Water	0.001	YES
4 2476123	Geller House, Staff BR next to Infirmary (Sink Faucet)	Water	0.015	YES

For all outlets that exceed the NYS Action Level action is required. In accordance with the Lead testing in School Drinking Water – 10 NYCRR Subpart 67-4, if lead is detected the school is obligated to:

- Prohibit use of the outlet until a remediation plan is implemented and test results indicate that the lead levels are at or below the action level.
- Provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed.
- Report the results to the local health department as soon as practicable but no more than 1 business day after the school received the laboratory report.

245 Albany Avenue • Thornwood • New York • 10594 • (914) 439-6513 • REGCOMP2@HOTMAIL.COM

---

Occupational

Safety

Environmental



- Notify all staff and all persons in parental relation to students of the test results in writing as soon as practicable but no more than 10 business days after the school received the laboratory report.
- The school shall make available the results of all lead testing performed and remediation plans implemented on its website as soon as practicable, but no later than 6 weeks after the school received the laboratory results.

Attached is the laboratory data sheet.

If there are any questions or further information is needed, please don't hesitate to contact me (914) 439-6513. Thank you for considering RegCom for your safety and compliance needs.


Sincerely,

Ernest C. Coon, MSc, RPIH, HEM

HCK.1015.17.IH

**Eastern Analytical Services, Inc.**  
**Water Sample Report**

RE: CPN HCK.100X-17-IH - Hawthorne Cedar Knolls UFSD - Sr/Jr High School,  
 Administration Building, Little School & Gellar House

Date Collected: 02/07/2017  
 Collected By: Louis Petty  
 Date Received: 02/07/2017  
 Date Analyzed: 02/08/2017  
 Analyzed By: Peter P. Argyrakis  
 Signature:   
 Analyte: Pb Water  
 Analytical Method: EPA 200.9  
 NYS Lab Number: 10851

Client: RegCom  
 245 Albany Avenue  
 Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
1 2476120	SR/JR High School - Room 209A - Staff Bathroom - Sink Faucet	Water	0.001 mg/L
2 2476121	Administration Building - Basement Staff - Bathroom #2 - Sink Faucet (From Left to Right)	Water	0.060 mg/L
3 2476122	Little School - Room 121 - Staff Lounge - Sink Faucet	Water	0.001 mg/L
4 2476123	Gellar House - Staff Bathroom - Next to Infirmary - Sink Faucet	Water	0.015 mg/L
Blank 2476124	Not Applicable	Water Blank	BDL < 0.001 mg/L

# RegCom

## Regulatory Compliance

Louis Petty  
Hawthorne Cedar Knolls UFSD  
226 Linda Avenue  
Hawthorne, NY 10594

November 9, 2016

Dear Mr. Petty:

Please find enclosed the retest/additional water testing report for the Hawthorne Cedar Knolls UFSD, Administration Building, Jr/Sr High School, Linden Hill High School, Geller House and the Little School. The investigation was completed on the 10/26/16.

### Sinks that exceeded the NYS Action Level of 0.015 mg/L:

#### Little School

Sample #	Location	Lead Conc.(mg/L)
1*	Room 121 – Staff Lounge Sink	0.053

#### Administration Building

Sample #	Location	Lead Conc.(mg/L)
2*	Basement Staff Bathroom Sink #2	0.084

#### Jr/Sr High School

Sample #	Location	Lead Conc.(mg/L)
4*	Room 209A – Staff Bathroom Sink	0.042

#### Geller House

Sample #	Location	Lead Conc.(mg/L)
13	Staff Bathroom Sink – Next to Infirmary Sink	0.261

**Note:** Sinks are counted from Left to right; \* = retest

**For all outlets that exceed the NYS Action Level action is required.** In accordance with the *Lead testing in School Drinking Water* – 10 NYCRR Subpart 67-4, if lead is detected:

- Prohibit use of the outlet until a remediation plan is implemented and test results indicate that the lead levels are at or below the action level.
- Provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed.

245 Albany Avenue Thornwood New York 10594  
Tel (914) 439-6513 Email: REGCOMP2@HOTMAIL.COM

Occupational

Safety

Environmental

COMPLIANCE IS SAFETY

- Report the results to the local health department as soon as practicable but no more than 1 business day after the school received the laboratory report.
- Notify all staff and all persons in parental relation to students of the test results in writing as soon as practicable but no more than 10 business days after the school received the laboratory report.

Attached is the laboratory data sheet. A hard copy will be mailed within the week.

If there are any questions or further information is needed, please do hesitate to contact me (914) 439-6513. Thank you for considering *RegCom* for your safety and compliance needs.

Sincerely,


Ernest C. Coon, MSc, RPIH, HEM

HCK.1143.16.IH

# Eastern Analytical Services, Inc.

## Water Sample Report

RE: CPN HCK-1143-16-IH - Hawthorne Cedar Knolls UFSD - Geller House

Date Collected: 10/26/2016  
Collected By: Lou Petty  
Date Received: 10/27/2016  
Date Analyzed: 11/03/2016  
Analyzed By: Peter P. Argyrakis  
Signature:   
Analyte: Pb Water  
Analytical Method: EPA 200.9  
NYS Lab Number: 10851

Client: RegCom  
245 Albany Avenue  
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
6 2462894	Kitchen - Sink #1 - Labeled Handwashing - Sink Faucet (From Left to Right)	Water - 1st Test	BDL < 0.001 mg/L
7 2462895	Kitchen - Sink #2 - Labeled Prep Sink - Sink Faucet (From Left to Right)	Water - 1st Test	BDL < 0.001 mg/L
8 2462896	Kitchen - #3 Sink - Labeled Wash/Rinse Sink - Sink Faucet (From Left to Right)	Water - 1st Test	0.001 mg/L
9 2462897	Handicapped Bathroom - Off Activity Room Near Porch Classroom - Sink Faucet	Water - 1st Test	0.001 mg/L
10 2462898	Rear Classroom Bathroom - Sink Faucet	Water - 1st Test	BDL < 0.001 mg/L
11 2462899	Girls Bathroom - At Top of Basement Stairs - Sink Faucet	Water - 1st Test	BDL < 0.001 mg/L
12 2462900	Boys Bathroom - At Top of Basement Stairs - Sink Faucet	Water - 1st Test	BDL < 0.001 mg/L
13 2462901	Staff Bathroom - Next to Infirmary - Sink Faucet	Water - 1st Test	0.261 mg/L
14 2462902	Not Applicable	Water Blank	BDL < 0.001 mg/L


BDL = Below Detectable Limits  
Liability Limited to Cost of Analysis  
Results Applicable to Those Items Tested  
AIHA Accreditation No. 418

Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

# Eastern Analytical Services, Inc.

## Water Sample Report

RE: CPN HCK-1143-16-IH - Hawthorne Cedar Knolls UFSD - Linden Hill High School

Date Collected: 10/26/2016  
Collected By: Lou Petty  
Date Received: 10/27/2016  
Date Analyzed: 11/03/2016  
Analyzed By: Peter P. Argyrakis  
Signature:   
Analyte: Pb Water  
Analytical Method: EPA 200.9  
NYS Lab Number: 10851

Client: RegCom  
245 Albany Avenue  
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
5 2462893	LH HS - Room 104 - CSE Office - Sink Faucet	Water - Retest	0.005 mg/L

**Eastern Analytical Services, Inc.**  
**Water Sample Report**

RE: CPN HCK-1143-16-IH - Hawthorne Cedar Knolls UFSD - Sr/Jr High School


Date Collected: 10/26/2016

Collected By: Lou Petty

Date Received: 10/27/2016

Date Analyzed: 11/03/2016

Analyzed By: Peter P. Argyrakis

Signature: 

Analyte: Pb Water

Analytical Method: EPA 200.9

NYS Lab Number: 10851

Client: RegCom

245 Albany Avenue

Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
4 2462892	SR JR HS - Room 209A - Staff Bathroom - Sink Faucet	Water - Retest	0.042 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis


Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

# Eastern Analytical Services, Inc.

## Water Sample Report

RE: CPN HCK-1143-16-IH - Hawthorne Cedar Knolls UFSD - Administration Building

Date Collected: 10/26/2016  
Collected By: Lou Petty  
Date Received: 10/27/2016  
Date Analyzed: 11/03/2016  
Analyzed By: Peter P. Argyrakis  
Signature:   
Analyte: Pb Water  
Analytical Method: EPA 200.9  
NYS Lab Number: 10851

Client: RegCom  
245 Albany Avenue  
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
2 2462890	Administration Building - Basement - Staff Bathroom #2 (From Left to Right) - Sink Faucet	Water - Retest	0.084 mg/L
3 2462891	Administration Building - Superintendent's Office - Bathroom - Sink Faucet	Water - Retest	0.004 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095



# Eastern Analytical Services, Inc.

## Water Sample Report

RE: CPN HCK-1143-16-IH - Hawthorne Cedar Knolls UFSD - Little School


Date Collected: 10/26/2016

Collected By: Lou Petty

Date Received: 10/27/2016

Date Analyzed: 11/03/2016

Analyzed By: Peter P. Argyrakis

Signature: 

Analyte: Pb Water

Analytical Method: EPA 200.9

NYS Lab Number: 10851

Client: RegCom

245 Albany Avenue

Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
1 2462889	Little School - Room 121 Staff Lounge - Sink Faucet	Water - Retest	0.053 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

# RegCom

## Regulatory Compliance

---

Louis Petty  
Hawthorne Cedar Knolls UFSD  
226 Linda Avenue  
Hawthorne, NY 10594

August 29, 2016

Dear Mr. Petty:

Please find enclosed the follow-up water testing report for the Hawthorne Cedar Knoll UFSD. The investigation was completed on the 9/24/16.

### Sinks that exceeded the NYS Action Level of 0.015 mg/L:

<u>Sample/Location</u>	<u>Lead Conc.(mg/L)</u>
6 LS Room 121/Staff lounge Sink	0.034
9 Adm Bldg Staff Bathroom Sink #2 (counting from left to right)	0.084
10 Adm Bldg Superintendent's Bathroom Sink	0.028
46 HS *Room 209A - Bathroom Sink	0.057
52 LHHS Room 104 Sink	0.017
62 LHHS Kitchen Sink #1(counting from left to right)/Rm 111A	0.034
64 LHHS Boiler Room Spigot Adjacent to Entrance	0.033

Note: LS = Little School; HS = High School; LH HS = Linden Hill High School

For all outlets that exceed the NYS Action Level action is required. In accordance with the *Lead testing in School Drinking Water – 10 NYCRR Subpart 67-4*, if lead is detected:

- Prohibit use of the outlet until a remediation plan is implemented and test results indicate that the lead levels are at or below the action level.
- Provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed.
- Report the results to the local health department as soon as practicable but no more than 1 business day after the school received the laboratory report.
- Notify all staff and all persons in parental relation to students of the test results in writing as soon as practicable but no more than 10 business days after the school received the laboratory report.

245 Albany Avenue Thornwood New York 10594  
Tel (914) 439-6513 [REGCOMP2@HOTMAIL.COM](mailto:REGCOMP2@HOTMAIL.COM) [WWW.REGCOMP.ORG](http://WWW.REGCOMP.ORG)

---

Occupational

Safety

Environmental

SAFETY IS COMPLIANCE

Attached is the laboratory data sheet. A hard copy will be mailed within the week.

If there are any questions or further information is needed, please do hesitate to contact me (914) 439-6513. Thank you for considering RegCom for your safety and compliance needs.

Sincerely,


Ernest C. Coon, MSc, RPIH, HEM

File: HCK .1108.16.IH

# Eastern Analytical Services, Inc.

## Water Sample Report

RE: CPN HCK-1108-16-IH - Hawthorne Cedar Knowles

Date Collected: 09/24/2016  
Collected By: S. Coon  
Date Received: 09/24/2016  
Date Analyzed: 10/03/2016  
Analyzed By: Peter P. Argyrakis  
Signature:   
Analyte: Pb Water  
Analytical Method: EPA 200.9  
NYS Lab Number: 10851

Client: RegCom  
245 Albany Avenue  
Thornwood, NY 10594


Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
1 2455386	Little School - Room 102 - Mens Room Sink	Water	0.003 mg/L
2 2455387	Little School - Room 103 - Womens Room Sink	Water	0.001 mg/L
3 2455388	Little School - Room 111 - (From Left to Right) Sink #1	Water	BDL < 0.001 mg/L
4 2455389	Little School - Room 113 - Sink	Water	BDL < 0.001 mg/L
5 2455390	Little School - Room 112 - Custodial Closet	Water	0.001 mg/L
6 2455391	Little School - Room 121 - Staff Lounge Sink	Water	0.034 mg/L
7 2455392	Little School - Room 120 - Sink	Water	0.010 mg/L
8 2455393	Administration Building - Staff Bathroom (From Left to Right) - Room #1 Sink	Water	0.003 mg/L
9 2455394	Administration Building Staff Bathroom - (From Left to Right) Room #2 Sink	Water	0.084 mg/L

BDL = Below Detectable Limits  
Liability Limited to Cost of Analysis  
Results Applicable to Those Items Tested  
AIHA Accreditation No. 418

Rhode Island DOH No. AAL-07273 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

**Eastern Analytical Services, Inc.**  
**Water Sample Report**

RE: CPN HCK-1108-16-IH - Hawthorne Cedar Knowles

Date Collected: 09/24/2016  
Collected By: S. Coon  
Date Received: 09/24/2016  
Date Analyzed: 10/03/2016  
Analyzed By: Peter P. Argyrakis  
Signature:   
Analyte: Pb Water  
Analytical Method: EPA 200.9  
NYS Lab Number: 10851


Client: RegCom  
245 Albany Avenue  
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
10 2455395	Administration Building Room #108 - Super's Office - Bathroom Sink	Water	0.028 mg/L
11 2455396	Administration Building - Business Office - Room 105 Sink	Water	0.012 mg/L
12 2455397	Dining Hall - Mens Bathroom Sink	Water	BDL < 0.001 mg/L
13 2455398	Dining Hall - Women's Bathroom Sink	Water	0.002 mg/L
14 2455399	Kitchen Solo Sink	Water	BDL < 0.001 mg/L
15 2455400	Kitchen (From Left to Right) Sink #1	Water	0.001 mg/L
16 2455401	Kitchen (From Left to Right) Sink #2	Water	0.002 mg/L
17 2455402	Kitchen (From Left to Right) Sink #3	Water	BDL < 0.001 mg/L
18 2455403	Kitchen (From Left to Right) Sink #4	Water	0.001 mg/L

# Eastern Analytical Services, Inc.

## Water Sample Report

RE: CPN HCK-1108-16-IH - Hawthorne Cedar Knowles

Date Collected: 09/24/2016  
Collected By: S. Coon  
Date Received: 09/24/2016  
Date Analyzed: 10/03/2016  
Analyzed By: Peter P. Argyrakis  
Signature:   
Analyte: Pb Water  
Analytical Method: EPA 200.9  
NYS Lab Number: 10851

Client: RegCom  
245 Albany Avenue  
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
19 2455404	High School - Custodial Closet - Room C - Room 001C - Sink	Water	0.007 mg/L
20 2455405	High School Mens Locker Room 004 - Sink (From Left to Right) Sink #1	Water	BDL < 0.001 mg/L
21 2455406	High School - Gym Lobby - East Water Fountain	Water	BDL < 0.001 mg/L
22 2455407	High School - Boys Bathroom 005 Sink	Water	BDL < 0.001 mg/L
23 2455408	High School - Girls Bathroom 007 Sink	Water	BDL < 0.001 mg/L
24 2455409	High School - Women's Locker Room 008 (From Left to Right) Sink #1	Water	0.001 mg/L
25 2455410	High School - Women's Locker Room 008 (From Left to Right) Sink #2	Water	0.001 mg/L
26 2455411	High School - Staff Lounge Room 003 Sink	Water	BDL < 0.001 mg/L
27 2455412	High School - Boiler Room 001B Hose/Spigot - Service Entry	Water	0.004 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis


Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

# Eastern Analytical Services, Inc.

## Water Sample Report

RE: CPN HCK-1108-16-IH - Hawthorne Cedar Knowles

Date Collected: 09/24/2016  
Collected By: S. Coon  
Date Received: 09/24/2016  
Date Analyzed: 10/03/2016  
Analyzed By: Peter P. Argyrakis  
Signature:   
Analyte: Pb Water  
Analytical Method: EPA 200.9  
NYS Lab Number: 10851


Client: RegCom  
245 Albany Avenue  
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
28 2455413	High School - Main Office Room 101A Sink	Water	BDL < 0.001 mg/L
29 2455414	High School - Main Office Bathroom 101D Sink	Water	BDL < 0.001 mg/L
30 2455415	High School - Outside Adjacent to Room 104 Water Fountain	Water	BDL < 0.001 mg/L
31 2455416	High School - 104A Staff Bathroom Sink	Water	0.006 mg/L
32 2455417	High School - 104B Staff Bathroom Sink	Water	0.001 mg/L
33 2455418	High School - Vocational Room 105 Sink	Water	BDL < 0.001 mg/L
35 2455419	High School - Bathroom 108A Sink	Water	BDL < 0.001 mg/L
37 2455420	High School - Bathroom 108D Sink	Water	BDL < 0.001 mg/L
38 2455421	High School - Bathroom 108E Sink	Water	0.004 mg/L

# Eastern Analytical Services, Inc.

## Water Sample Report

RE: CPN HCK-1108-16-IH - Hawthorne Cedar Knowles

Date Collected: 09/24/2016  
Collected By: S. Coon  
Date Received: 09/24/2016  
Date Analyzed: 10/03/2016  
Analyzed By: Peter P. Argyrakis  
Signature:   
Analyte: Pb Water  
Analytical Method: EPA 200.9  
NYS Lab Number: 10851

Client: RegCom  
245 Albany Avenue  
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
39 2455422	High School - Outside Room 205 Water Fountain	Water	BDL < 0.001 mg/L
40 2455423	High School - Bathroom 205A Sink	Water	0.009 mg/L
41 2455424	High School - Bathroom 205B Sink	Water	0.014 mg/L
42 2455425	High School - Room 206 (From Left to Right) Sink #1	Water	BDL < 0.001 mg/L
43 2455426	High School - Room 206 (From Left to Right) Sink #2	Water	BDL < 0.001 mg/L
44 2455427	High School - Room 206 (From Left to Right) Sink #3	Water	BDL < 0.001 mg/L
45 2455428	High School - Water Fountain Outside Room 209	Water	BDL < 0.001 mg/L
46 2455429	High School - Bathroom 209A Sink (Only Hot Water Functions)	Water	0.057 mg/L
47 2455430	High School - Bathroom 209B Sink	Water	BDL < 0.001 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested


AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095



# Eastern Analytical Services, Inc.

## Water Sample Report

RE: CPN HCK-1108-16-IH - Hawthorne Cedar Knowles

Date Collected: 09/24/2016  
Collected By: S. Coon  
Date Received: 09/24/2016  
Date Analyzed: 10/03/2016  
Analyzed By: Peter P. Argyrakis  
Signature:   
Analyte: Pb Water  
Analytical Method: EPA 200.9  
NYS Lab Number: 10851

Client: RegCom  
245 Albany Avenue  
Thornwood, NY 10594


Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
48 2455431	High School - Bathroom Sink 209D	Water	BDL < 0.001 mg/L
49 2455432	High School - Bathroom Sink 209E	Water	BDL < 0.001 mg/L
50 2455433	Linden Hill High School - Art Room 103 (From Left to Right) Sink #1	Water	0.002 mg/L
51 2455434	Linden Hill High School - Art Room 103 (From Left to Right) Sink #2	Water	BDL < 0.001 mg/L
52 2455435	Linden Hill High School - Room 104 Sink	Water	0.017 mg/L
53 2455436	Linden Hill High School - Bathroom 106 Sink	Water	BDL < 0.001 mg/L
54 2455437	Linden Hill High School - Bathroom 107 Sink	Water	BDL < 0.001 mg/L
55 2455438	Linden Hill High School - Bathroom 108 (From Left to Right) Sink #1	Water	0.001 mg/L
56 2455439	Linden Hill High School - Bathroom 108 (From Left to Right) Sink #2	Water	0.002 mg/L

BDL = Below Detectable Limits  
Liability Limited to Cost of Analysis  
Results Applicable to Those Items Tested

# Eastern Analytical Services, Inc.

## Water Sample Report

RE: CPN HCK-1108-16-IH - Hawthorne Cedar Knowles

Date Collected: 09/24/2016  
Collected By: S. Coon  
Date Received: 09/24/2016  
Date Analyzed: 10/03/2016  
Analyzed By: Peter P. Argyrakis  
Signature:   
Analyte: Pb Water  
Analytical Method: EPA 200.9  
NYS Lab Number: 10851

Client: RegCom  
245 Albany Avenue  
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
57 2455440	Linden Hill High School - Bathroom 110 Sink #1	Water	0.001 mg/L
58 2455441	Linden Hill High School - Bathroom 110 Sink #2	Water	0.001 mg/L
59 2455442	Room 111 - Sink #1	Water	0.001 mg/L
60 2455443	Linden Hill High School - Room 111 Sink 2	Water	BDL < 0.001 mg/L
61 2455444	Linden Hill High School - Room 111 Sink 3	Water	BDL < 0.001 mg/L
62 2455445	Linden Hill High School - Kitchen 111A Sink 1	Water	0.034 mg/L
63 2455446	Linden Hill High School - Kitchen 111A Sink 2	Water	0.010 mg/L
64 2455447	Linden Hill High School - Boiler Room - Spigot Adjacent to Entrance	Water	0.033 mg/L
65 2455448	Linden Hill High School - Water Fountain Outside 116	Water	BDL < 0.001 mg/L

BDL = Below Detectable Limits


Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

**Eastern Analytical Services, Inc.**  
**Water Sample Report**

RE: CPN HCK-1108-16-IH - Hawthorne Cedar Knowles

Date Collected: 09/24/2016  
 Collected By: S. Coon  
 Date Received: 09/24/2016  
 Date Analyzed: 10/03/2016  
 Analyzed By: Peter P. Argyrakis  
 Signature:   
 Analyte: Pb Water  
 Analytical Method: EPA 200.9  
 NYS Lab Number: 10851

Client: RegCom  
 245 Albany Avenue  
 Thornwood, NY 10594


Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
66 2455449	Linden Hill High School - 116B Sink	Water	BDL < 0.001 mg/L
67 2455450	Linden Hill High School - 116D Sink	Water	BDL < 0.001 mg/L
68 2455451	Linden Hill High School - 116E Sink	Water	0.001 mg/L
69 2455452	207 Sink	Water	BDL < 0.001 mg/L
70 2455453	Linden Hill High School - Water Fountain Outside Room 208	Water	BDL < 0.001 mg/L
71 2455454	Linden Hill High School - 208B Sink	Water	BDL < 0.001 mg/L
72 2455455	Linden Hill High School - 208D Sink	Water	BDL < 0.001 mg/L
73 2455456	Linden Hill High School - 208E Sink	Water	BDL < 0.001 mg/L
74 2455457	Linden Hill High School - 213B Sink	Water	BDL < 0.001 mg/L

BDL = Below Detectable Limits  
 Liability Limited to Cost of Analysis  
 Results Applicable to Those Items Tested

# Eastern Analytical Services, Inc.

## Water Sample Report

RE: CPN HCK-1108-16-IH - Hawthorne Cedar Knowles

Date Collected: 09/24/2016  
Collected By: S. Coon  
Date Received: 09/24/2016  
Date Analyzed: 10/03/2016  
Analyzed By: Peter P. Argyrakis  
Signature:   
Analyte: Pb Water  
Analytical Method: EPA 200.9  
NYS Lab Number: 10851

Client: RegCom  
245 Albany Avenue  
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
75 2455458	Linden Hill High School - 213D Sink	Water	0.001 mg/L
76 2455459	Linden Hill High School - 213E Sink	Water	BDL < 0.001 mg/L
77 2455460	Linden Hill - Gym - Boys Room Sink	Water	0.010 mg/L
78 2455461	Linden Hill - Gym - Girls Room Sink	Water	BDL < 0.001 mg/L
79 2455462	Not Applicable	Water Blank	BDL < 0.001 mg/L